



WASTE WATER TREATMENT PLANT

32360 Warkop
Warren, Michigan 48093-6726
(586) 264-2530
Fax (586) 264-3594
www.cityofwarren.org

MEMO TO: Warren City Council Secretary

FROM: Anthony Conigliaro, WWTP Division Head
Division of Wastewater Treatment

SUBJECT: CONSIDERATION AND ADOPTION OF RESOLUTION to Award Sole Source and Approve EME-W-1880 – Purchase & Installation of one (1) Right-Hand Auger, one (1) Left-Hand Auger and one (1) Dual-Augur Transmission to Duperon Corporation, in the total amount not to exceed \$29,337.00 and authorizing Mayor and Clerk to execute.

DATE: 05/12/2026

The Waste Water Treatment Plant is seeking immediate approval for the replacement and installation of one (1) Right-Hand Auger, one (1) Left-Hand Auger and one (1) Dual-Augur Transmission from Duperon Corporation. Duperon Corporation is the sole source provider for all Duperon branded service parts and all associated accessories for Michigan. Attached please find a sole source letter from Duperon Corporation and a pricing quote for the requested Augers, Transmission Unit and installation in the total amount of \$29,337.00.

On May 11, 2026, WWTP Personnel were investigating a sudden halt of operations with our large compactor, located in at the bottom of the Wet Well at WWTP. Upon further review and with removal of the discharge pipe, it was discovered that both augers and the transmission unit had broken, not allowing the compactor to remove and dispose of any large debris collecting along the bar screens at the bottom. Without this piece of equipment in operation, any and all debris collecting at the bottom will not be properly disposed of and could result in further damage to the compactor creating a safety & health concern not only for city employees, but for residents as well.

Time is of the essence to replace these components as this compactor is the first line of defense for preventing all large debris from entering the system and damaging any further components in the water treatment process.

Please take the steps necessary to authorize immediate approval for this sole source purchase from Duperon Corporation, 1200 Leon Scott Ct, Saginaw, MI 48601-1273, in the total amount of \$29,337.00


Funds for the procurement and installation of these components is available in the FY26 Budget, Account #592-1580-93001.

Thank you in advance for your assistance on this request. Should you have any questions, I can be reached directly at extension 8103.

Sincerely,

Read & Concurred:

Read & Concurred:

DocuSigned by:

FCFF4B48450F471...
Anthony Conigliaro
WWTP Division Head

DocuSigned by:


A310A808B8C84DD...
Dave Muzzarelli
Public Service Director


Signed by:

E610E2D7FFE5449...
Craig Treppa
Purchasing Director

Read & Concurred

Read & Concurred:

Signed by:

F0FDC83AE1C142B...
Kristina Battle
Budget Director

Signed by:

F040B73E57F248E...
Lori Stone
Mayor

æk

Attachments: Pairing Quote, City Council Resolution, Sole Source Letter from Duperon

- cc: J. Jenkins, Facility Eng
D. Dordeski, Env. Eng
M. Frick, WWTP Eng
R. Hilliard, WWTP Maint. Supervisor
D. Muzzarelli, P.S Director

RESOLUTION

Document No: EME-W-1880
Product or Service: Large Compactor Repair
Requesting Department: Waste Water Treatment Plant

At a regular meeting of the City Council of the City of Warren, County of Macomb, Michigan, held on _____, 2026 at 7 p.m. Easter Daylight Savings Time, in Council Chambers located at the Warren Community Center, Conference Room A, 5460 Arden Ave, Warren, Michigan.

PRESENT: Councilpersons _____

ABSENT: Councilpersons _____

The following preamble and resolution were offered by Councilperson _____ and supported by Councilperson _____.

On May 11, 2026, WWTP Personnel were investigating a sudden stoppage in the large compactor, located in the Wet Well at WWTP. Upon removal of the discharge pipe, it was discovered that the two augers and transmission unit had broken, not allowing the compactor to process and dispose of any large debris collecting along the bar screens at the bottom of the compactor.

Replacement of these components are crucial in the continued treatment and operations of WWTP as the large compactor is the first line of defense for preventing any large debris from entering the system and damaging other components, such as pumps & motors.

The WWTP Division Head and WWTP Maintenance Supervisor has recommended to use Sole Source Provider, Duperon Corporation, 1200 Leon Scott Ct, Saginaw, MI 48061-

1273, for the replacement and installation of these components in the quoted amount of \$29,337.00.

Duperon Corporation is the sole source provider for all Duperon branded service parts and all associated accessories in Michigan.

Funding is available in the 2026 Water & Sewer System budget, Waste Water Treatment Plant, Account 592-1580-93001.

THEREFORE, BE IT RESOLVED, pursuant to the recommendation of the Division Head, that the purchase of replacement components and repair of the large compactor from the sole source provider, Duperon Corporation is hereby accepted by City Council in the total amount of \$29,337.00.

BE IT FURTHER RESOLVED, that the Purchasing Agent and/or Mayor and City Clerk are authorized to execute any such documents that are necessary for this approval consistent with the terms of the:

- Bid Document
- Contract
- Resolution

and in such form that meets with the satisfaction of the City Attorney if review is required.

AYES: Councilpersons: _____

NAYS: Councilpersons: _____

RESOLUTION DECLARED ADOPTED this _____ day of _____, 2026.

Mindy Moore
Secretary of the Council



ISSUE PO TO

Duperon Corporation
 1200 Leon Scott Ct
 Saginaw, MI 48601-1273

Phone: 800-383-8479
Fax: 989-754-2175

QUOTE

NUMBER: S4553
 REVISION: -
 DATE: 5/11/2026

BILL TO

City of Warren (Purchasing Division)
 One City Square, Suite 425
 Warren, MI 48093 US


SHIP TO

City of Warren
 32360 Warkop Road
 Warren, MI 48093 US

CUST. NO.	FOB SHIPMENT	ROUTING	TERMS	SALES PERSON
4497	JOBSITE		Net 30 Days	Ron Clor

ITEM	PART NUMBER	EXPECTED SHIP DATE	QUANTITY	UNIT PRICE	UOM	TOTAL PRICE
	DESCRIPTION					
001	WC.D.095.5.0.0 AUGER: WC3.X3 64" RH 304SS Hardened		1	\$8,911.00	EA	\$8,911.00
002	WC.D.096.5.0.0 AUGER: WC3.X3 64" LH 304SS Hardened		1	\$8,911.00	EA	\$8,911.00
003	WC.S.TADA.5.0.0 TRANSMISSION ASM: DUAL AUGER 304SS		1	\$7,615.00	EA	\$7,615.00
004	113F0200 TAPER GRIP BUSHING, 2" WC - STD "B" BOX		1	\$700.00	EA	\$700.00
005	TECH SUPPORT-TR Tech Support - Travel plus expenses		2	\$1,600.00	EA	\$3,200.00
- Shipping and Taxes Not Included - Quote Effective for 60 days - Returns are subject to a 20% restocking fee - Custom fabricated parts are not returnable - Electronic parts are not returnable unless unopened and unprogrammed - Credit Card Transactions carry a 4% Surcharge - Right of Refusal: Due to volatility in supplier markets, Duperon Corporation reserves the right to revise, withdraw, or negotiate this quote at any time prior to acceptance.						

TOTAL FOR QUOTE in USD: \$29,337.00



January 26, 2026

Warren MI

RE: Sole Source

To Whom It May Concern,

Per your request, the intent of this letter is to confirm that Duperon Corporation® is the sole source for the Duperon® branded service parts and all associated accessories in Michigan. These products are a proprietary design of Duperon Corporation and are not manufactured under license or other arrangement by any other manufacturer or supplier.

If you have any further questions or concerns, please do not hesitate to contact me at 800.383.8479 or Ron Clor rclor@duperon.com

Thank you,

Ron Clor

Service Manager

Form SV-P07-F01-00 4-2-24.